

C O N S I G N E E
INTERMOUNTAIN POWER
850 WEST BRUSH WELLMAN ROAD
DELTA, UT 84624

S H I P P E R
PTC AIR FREIGHT, INC
15 N ORANGE ST
P.O. BOX AMF22145
SALT LAKE CITY, UT 84122



40015139
496 North 1300 E
St. George, Utah 84
800-748-4110

B I L L T O
PTC AIR FREIGHT, INC.
15 N ORANGE ST
P.O. BOX AMF22145
SALT LAKE CITY, UT 84122

DATE 3/21/05
SHIPPER'S NUMBER 366558

ORIGIN C/L		PRO NUMBER	DATE	I/C POINT	BYD C/L	C.O.D.	NON REC. REV	PAYABLE	AMOUNT DUE
						\$0.00		\$0.00	
# PIECES	H/M	DESCRIPTION					WEIGHT	RATE	TOTAL CHARGE
1		PC SPARE PART					150		
		FUEL SURCHARGE							
		ATTN: JOHN CHRISTENSEN 435-884-6481							
		FAX POD TO SLC ASAP							
1		PREPAID					150		
Totals							150		
A VALUE NOT EXCEEDING \$50.00 UNLESS THE VALUE OF SHIPMENT IS STATED IN VALUATION BOX AT RIGHT AND 25 CENTS PER \$50.00 OR FRACTION THEREOF IS ASSESSED, A FINANCE CHARGE OF 1 1/2% PER MONTH (ANNUAL PERCENTAGE RATE 18%) OF THE UNPAID BALANCE WILL BE ADDED MONTHLY. SHOULD COLLECTION BECOME NECESSARY, THE RESPONSIBLE PARTY AGREES TO PAY ALL COLLECTION FEES, AND ALL LEGAL FEES OF COLLECTION, WITH OR WITHOUT SUIT, INCLUDING ATTORNEY FEES AND COURT COSTS.							VALUATION		
							\$	\$0.00	

DRIVERS SIGNATURE By LOLH CHECK CASH 11:00 PCS DEL 1 DATE 3, 22, 05 RECEIVED IN GOOD CONDITION EXCEPT AS OTHERWISE NOTED. By E. Suffer DATE 3 22

Al Stom's
Commissioning
Parts

IP7 025939

ALSTOM

Tel.: (412) 967-0765
Fax: (412) 967-7661

ADVICE NOTE

No. 11

Ship Date: 3/14/2005

Project No.: GD70116

Please reference above on all communication

Custom: Intermountain Power Service Corp.
850 W. Brush Wellman Road
Delta, UT 84624-9546

Attention: John Christensen
435-864-6481

Customer Order No.: 05-41041

Ship to: (if different than customer address)

Carrier:
Waybill No.: Pro No.

Item	Qty	Customer Part No.	Description of Goods	Serial Number and/or Comments
1	0	M91141/001	Signet Flow meter	previously shipped
2	0	G310C000	Red Lion HMI	previously shipped
3	0	M78309/007	Power Supply, 24V DC	previously shipped
4	0	M78309/003	Power Supply, 24V DC	previously shipped
5	0	M86900/001	24Vdc Digital Signal Isolator	previously shipped
6	0	M86408/003	12Vdc Telemecanique relay	previously shipped
7	0	M86408/006	24Vdc Telemecanique relay, 2NO, 2NC	previously shipped
8	0	CA3-KN40BD3	24Vdc Telemecanique relay, 4NO	previously shipped
9	0	CA3-KN31BD3	24Vdc Telemecanique relay, 3NO, 1NC	previously shipped
10	0	M86408/009	48Vdc Telemecanique relay	previously shipped
11	0	M84513/001	120Vac Siemens Relay, w/aux. Contact	previously shipped
12	0	3RV1021-1CA10	Siemens Thermal Overload/Disconnect Relay	previously shipped
13	0	8501-C022V20	120Vdc Square D (BKTP) relay	previously shipped
14	0	1SVR450125R0000	Ground Fault relay	previously shipped
15	0	M84050/218	Exciter Contactor	previously shipped
16	0	M84050/103	Exciter Contactor Suppressor	previously shipped
17	0	M98601/001	Strip Heater	previously shipped
18	1	M86701/001	Moisture Detection Sensor	
19	0	M86700/001	Moisture Detection Relay	previously shipped
20	0	560-252-1	2500:1 Current Transformer	previously shipped
21	0	28 14 05 8	Phoenix 3-Way Isol Amplifier MCR-CLP-UI-4	previously shipped
22	0	M59100/001	Deionization Tank	previously shipped
23	0	M73329/00X	Thyristor	previously shipped
24	0	M47104/002	Filter, paper, 10", 20 micron	previously shipped
25	0	M78001/208	Gating Board	previously shipped
25	0	M78001/208	Gating Board	previously shipped
25	0	M78001/208	Gating Board	previously shipped
26	0	9782C-S0-C2-E0000-BD	Conductivity Analyzer	previously shipped

Note: This shipment completes spares per items 1 & 2 of September 29, 2004 letter to increase the contract value. Item 18 had been used to replace the unit damaged during installation of the replacement regulator panels in drive 2D and was unavailable to ship until now.

Page 1 of 1

Number: CF40600
Revision: B
File name: CF40600-B.xls

ALSTOM Power Conversion
610 Epsilon Drive
Pittsburgh PA 15238 USA

IP7_025940